

SKG-IKOB PRODUCTCERTIFICATE

404.841.02

Date of issue: 12-07-2019



Certificate holder

Fuhr GmbH & Co KG
Carl Fuhr Straße 12
D-42579 Heiligenhaus
T: +49 (0) 2056 5920
E: info@fuhr.de
I: www.fuhr.de



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

rim bolt with keeper

delivered under logo / brand:

FUHR

delivered under type- and / or article number:

DZ 150 SEW

meets class 1 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

1. PRODUCT
rim bolt with keeper

PRODUCT TYPE
single bolt

2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	linkable frame -/ and leaf part
System:	pen with hex key
Material:	frame and leaf part: steel coated
Dimension:	frame-part: 142x15x15 mm leaf-part L: 49x17x3x57 mm
Fixing:	frame-part: 3X pvc 4,8x25 / wood 4,5x40 mm leaf-part: 5X pvc 4,8x25 / wood 4,5x40 mm
Intended use:	wood, PVC, door-inward-opening, window-inward-opening for windows and doors

3. DELIVERY

The delivery includes an installation instruction:
D9M1_06.19-9

4. PERFORMANCES

A rim bolt with keeper according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this rim bolt with keeper is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this rim bolt with keeper is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-